

## APPENDIX

### Email from Committee of Adjustment Staff (Forestry) with respect to tree conservation on the subject site:

**From:** Young, Nancy <Nancy.Young@ottawa.ca>  
**Sent:** May 1, 2023 10:30 AM  
**To:** Shannon, Luke <luke.shannon@ottawa.ca>  
**Cc:** Committee of Adjustment / Comité de dérogation <cota@ottawa.ca>  
**Subject:** RE: Forestry Study for lot severance

Hi Luke,

Thank you for confirming the measurements. As the tree is <50cm it is not protected under the by-law, and no Tree Information Report is required.

It is still always encouraged to plan and work around existing trees to allow for their retention and maintain the value they provide to the site. More information can be found on the 'Planning Around Trees' link in the email below, but the main priority is to protect the area within 4.3m of the tree by designing your project outside of this area and installing fencing as per the attached specifications.

Nothing further is required at this time. I have copied the Committee of Adjustment on this email to confirm that no TIR is required with this application.

Thanks,  
Nancy



Nancy Young, RPF  
Planning Forester  
Natural Systems and Rural Affairs, PRED  
110 Laurier Ave W, Ottawa, ON K1P 1A1  
nancy.young@ottawa.ca 613-580-0424 ext. 13581

Committee of Adjustment  
Received | Reçu le

2023-08-09

City of Ottawa | Ville d'Ottawa  
Comité de dérogation