

2024-11-14



CONSENT APPLICATION

COMMENTS TO THE COMMITTEE OF ADJUSTMENT

PANEL 1

PLANNING, DEVELOPMENT AND BUILDING SERVICES DEPARTMENT

Site Address: 285 Montfort Street
Legal Description: Lot 252 and Part of Lot 251, Registered Plan 246
File No.: D08-01-24/B-000219
Report Date: November 14, 2024
Hearing Date: November 20, 2024
Planner: Penelope Horn
Official Plan Designation: Inner Urban Transect, Neighborhood
Zoning: R4UA

DEPARTMENT COMMENTS

The Planning, Real Estate and Economic Development Department **has no concerns with** the application.

DISCUSSION AND RATIONALE

Section 53 (12) of the *Planning Act*, R.S.O. 1990, c. P.13, as amended, permits the criteria for the subdivision of land listed in Section 51 (24) to be considered when determining whether provisional consent may be granted by a committee of adjustment. With respect to the criteria listed in Section 51 (24), staff have no concerns with the proposed consent to allow separate ownership of each half of a semi-detached dwelling on two zoning compliant lots.

ADDITIONAL COMMENTS

Planning Forestry

A Tree Removal Permit (102000415) was issued for the privately-owned distinctive tree on site prior to construction, conditional on the planting of three replacement trees. A tree planting plan for 285 Montfort must be provided and implemented, or proof must be provided showing that the replacement trees have been planted on site.

Additionally, to enhance the streetscape and contribute towards the City's 40% canopy goal, trees must be planted in the right-of-way following construction, in line with the Official Plan's policies to enhance and protect the urban forest canopy through growth and intensification (§ 4.8.2).

Transportation Engineering

The City of Ottawa is planning an integrated renewal (reconstruction of road, sidewalks, sewers and watermains) on Montfort Street between Marier Avenue and Alfred Street, which is anticipated to start construction in 2026 at the earliest. Traffic calming measures (vertical and horizontal) will be proposed to achieve a 30 km/h operating speed. Contact René Monast (Asset Management) for additional project information and coordination.

CONDITIONS

If approved, the Planning, Real Estate and Economic Development Department requests that the Committee of Adjustment impose the following conditions on the application:

1. That the Owner(s) provide evidence that payment has been made to the City of Ottawa for cash-in-lieu of the conveyance of land for park or other public recreational purposes, plus applicable appraisal costs. The value of land otherwise required to be conveyed shall be determined by the City of Ottawa in accordance with the provisions of By-Law No. 2022-280, as amended. Information regarding the appraisal process can be obtained by contacting the Planner.
2. That the Owner(s) provide evidence to the satisfaction of both the Chief Building Official and Development Review Manager, Planning, Development and Building Services Department, or designates, that both severed and retained parcels have their own independent water, sanitary and storm connection as appropriate, and that these services do not cross the proposed severance line and are connected directly to City infrastructure. Further, the Owner(s) shall comply to 7.1.5.4(1) of the Ontario Building Code, O. Reg. 332/12 as amended. If necessary, a plumbing permit shall be obtained from Building Code Services for any required alterations.
3. That the Owner(s) enter into a Joint Use, Maintenance and Common Elements, at the expense of the Owner(s), setting forth the obligations between the Owner(s) and the proposed future owners.

The Joint Use, Maintenance and Common Elements Agreement shall set forth the joint use and maintenance of all common elements including, but not limited to, the common party walls, common structural elements such as roof, footings, soffits, and foundations.

The Owner shall ensure that the Agreement is binding upon all the unit owners and successors in title and shall be to the satisfaction of Development Review All Wards Manager within Planning, Development and Building Services Department, or their designate, or City Legal Services. The Committee requires written

confirmation that the Agreement is satisfactory to Development Review All Wards Manager of the Development Review All Wards Branch within Planning, Development and Building Services Department, or their designate, or is satisfactory to City Legal Services, as well as a copy of the Agreement and written confirmation from City Legal Services that it has been registered on title.

4. That the Owner(s) shall provide evidence that a grading and drainage plan, prepared by a qualified Civil Engineer licensed in the Province of Ontario, an Ontario Land Surveyor or a Certified Engineering Technologist, has been submitted to the satisfaction of Development Review All Wards Manager of the Development Review All Wards Branch within Planning, Development and Building Services Department, or their designate to be confirmed in writing from the Department to the Committee. The grading and drainage plan shall delineate existing and proposed grades for both the severed and retained properties, to the satisfaction of Development Review All Wards Manager of the Development Review All Wards Branch within Planning, Development and Building Services Department, or their designate.
5. That the Owner/Applicant(s) provide and implement a tree planting plan, prepared to the satisfaction of the Manager of the relevant Branch within the Planning, Real Estate and Economic Development Department, or their designate(s), showing the location(s) and species or ultimate size of all compensation trees required under the Tree Protection By-law and/or one new tree (50 mm caliper) per lot.
6. That the Owner(s) provide evidence to the satisfaction of the Chief Building Official, or designate, that the party wall meets the Ontario Building Code, O Reg. 332/12 as amended, which requires a 1-hour fire separation from the basement through to the underside of the roof. Verification from the Building Inspector is required. If necessary, a building permit shall be obtained from Building Code Services for any required alterations.



Penelope Horn
Planner I, Development Review All Wards
Planning, Development and Building



Erin O'Connell
Planner III, Development Review All Wards
Planning, Development and Building

Services Department

Services Department

110 Laurier Avenue West, Ottawa ON K1P 1J1 Mail code: 01-14
110, av. Laurier Ouest, Ottawa (Ontario) K1P 1J1 Courrier interne : 01-14

Visit us: Ottawa.ca/planning
Visitez-nous : Ottawa.ca/urbanisme