

2025-01-30



CONSENT & MINOR VARIANCE APPLICATION
COMMENTS TO THE COMMITTEE OF ADJUSTMENT
PANEL 1

PLANNING, DEVELOPMENT AND BUILDING SERVICES DEPARTMENT

Site Address: 60 Hampton Avenue
Legal Description: Lot 2769, Registered Plan M-47
File No.: D08-01-24/B-00275, D08-02-24/A-00318, & D08-02-24/A00319
Report Date: January 30, 2025
Hearing Date: February 05, 2025
Planner: Penelope Horn
Official Plan Designation: Inner Urban Transect, Neighbourhood Designation, Evolving Neighbourhood Overlay
Zoning: R3K

DEPARTMENT COMMENTS

The Planning, Real Estate and Economic Development Department **requests an adjournment of** the application. An additional variance is needed in order to allow an attached front-facing garage, where the Streetscape Character Analysis does not permit and attached front-facing garage.

DISCUSSION AND RATIONALE

Section 53 (12) of the *Planning Act*, R.S.O. 1990, c. P.13, as amended, permits the criteria for the subdivision of land listed in Section 51 (24) to be considered when determining whether provisional consent may be granted by a committee of adjustment. With respect to the criteria listed in Section 51 (24), staff have no concerns with the proposed consent.

Lot Width and Lot Area

Staff are satisfied that the proposed reduction to the lot width and lot area still allow for the creation of a functional lot and aligns with the diverse lot patterns which characterize the Inner Urban Transect.

Rear Yard Setback and Rear Yard Area

The reduction of the rear yard setback and rear yard area still allow for the retention of a distinctive tree along the rear lot line. The current plan allows for intensive soft landscaping in the rear yard.

Garage Variances

Staff are not satisfied that the introduction of two front-facing garages meet the four tests. The subject site is zoned R3I within the Mature Neighbourhoods Overlay, and is subject to the Streetscape Character Analysis. The analysis identified that the subject lot is part of Character Group A, where front-facing attached garages are not permitted. Staff have some concerns regarding the requested front-facing attached garages. In this transect, the Official Plan prioritizes the built-form relationship with the public realm through emphasis on front entrances and windows. It directs parking to be hidden from the view of the public realm, so as to reduce the dominance of the automobile on the streetscape. The proposed attached garages render the principal entrance of less importance and may contribute to the dominance of the automobile within this neighbourhood.

ADDITIONAL COMMENTS

Infrastructure Engineering

- The **Planning, Development and Building Services Department** will do a complete review of grading and servicing during the building permit process.
- At the time of building permit application, a grading/servicing plan prepared by a Professional Engineer, Ontario Land surveyor or a Certified Engineering Technologist will be required.
- Any proposed works to be located within the road allowance requires prior written approval from the Infrastructure Services Department.
- The surface storm water runoff including the roof water must be self contained and directed to the City Right-of-Way, not onto abutting private properties as approved by **Planning, Development and Building Services Department**.
- A private approach permit is required for any access off of the City street.
- Existing grading and drainage patterns must not be altered.
- Existing services are to be blanked at the owner's expense.
- Asphalt overlay would be required if three or more road-cuts proposed on City Right of way. This includes the road cut for blanking of existing services, and any other required utility cuts (ie, gas, hydro, etc.).
- Existing Catch Basin is not to be located within the driveway.
- Service lateral spacing shall be as specified in City of Ottawa Standard S11.3.
- In accordance with the Sewer Connection By-Law a minimum spacing of 1.0m is required between service laterals and the foundation face.
- If required, existing street sign to be relocated at the owner's expense.

Planning Forestry

There are no tree-related concerns with the variances or severance requested. The plans have been designed to allow for the retention of tree #1, A City tree, and the rear

yard provides sufficient setback to retain boundary tree #2. Securities will be required for the protection of tree #1 and a planting plan must be provided showing one new 50mm tree per lot to improve the streetscape and canopy cover following development.

Right-of-Way

The Right-of-Way Management Department has no concerns with the proposed Consent and Minor Variance Applications. The Owner shall be made aware however, that a private approach permit is required to construct any new entrance, as well as to modify or close an existing entrance that becomes redundant. **As a result of the planned changes to private approaches, the Owner must contact the ROW Department for further information at rowadmin@ottawa.ca.**

CONDITIONS

If approved, the Planning, Real Estate and Economic Development Department requests that the Committee of Adjustment impose the following conditions on the applications:

1. That the Owner(s) provide evidence that payment has been made to the City of Ottawa for cash-in-lieu of the conveyance of land for park or other public recreational purposes, plus applicable appraisal costs. The value of land otherwise required to be conveyed shall be determined by the City of Ottawa in accordance with the provisions of By-Law No. 2022-280, as amended. Information regarding the appraisal process can be obtained by contacting the Planner.
2. That the Owner(s) provide evidence, to the satisfaction of both the Chief Building Official and the Manager of Development Review All Wards Branch within Planning, Development and Building Services Department, or their designates, that both severed and retained parcels have their own independent water, sanitary and storm connection as appropriate, that these services do not cross the proposed severance line and are connected directly to City infrastructure. Further, the Owner(s) shall comply to 7.1.5.4(1) of the Ontario Building Code, O. Reg. 332/12 as amended. If necessary, a plumbing permit shall be obtained from Building Code Services for any required alterations.
3. That the Owner(s) provide proof that a grading and drainage plan, prepared by a qualified Civil Engineer, licensed in the Province of Ontario, an Ontario Land Surveyor or a Certified Engineering Technologist, delineating the existing and proposed grades for both the severed and retained lands has been provided to the satisfaction of the Manager of Development Review All Wards Branch within Planning, Development and Building Services Department, or their designate.
4. The Owner(s) shall:
Prepare a Noise Control Study, in compliance with the City of Ottawa Environmental Noise Control Guidelines, to the satisfaction of the the Manager of

Development Review All Wards Branch within Planning, Development and Building Services Department, or their designate. The Owner(s) shall enter into an agreement with the City, at the expense of the Owner(s), that requires the Owner(s) to implement any Noise Control Study attenuation measures recommended in the approved study. The Agreement shall also deal with any covenants/notices, recommended in the approved study, that shall run with the land and bind future owners on subsequent transfers, warning purchasers and/or tenants of expected noise levels due to the existing source of environmental noise (arterial, highway, airport, etc.). The Committee shall be provided a copy of the Agreement and written confirmation from City Legal Services that it has been registered on title.

or

Design the dwelling units with the provision for adding central air conditioning at the occupant's discretion and enter into an Agreement with the City, at the expense of the Owner, which is to be registered on title to deal with the covenants/ notices that shall run with the land and bind future owners on subsequent transfers, warning purchasers and/or tenants of expected noise levels due to the existing source of environmental noise. The Committee requires a copy of the Agreement and written confirmation from City Legal Services that it has been registered on title. The following two conditions will be included in the above-noted Agreement:

Notices-on-Title respecting noise:

- i) "The Purchaser/Lessee for himself, his heirs, executors, administrators, successors and assigns acknowledges being advised that this dwelling unit has been fitted with a forced air heating system and the ducting, etc. was sized to accommodate central air conditioning. Installation of central air conditioning by the Purchaser/Lessee will allow windows and exterior doors to remain closed, thereby ensuring that the indoor sound levels are within the City of Ottawa's and the Ministry of the Environment and Climate Change's noise criteria;" and
 - ii) "The Purchaser/Lessee for himself, his heirs, executors, administrators, successors and assigns acknowledges being advised that noise levels due to increasing roadway traffic may be of concern, occasionally interfering with some activities of the dwelling occupants as the outdoor sound level exceeds the City of Ottawa's and the Ministry of the Environment and Climate Change's noise criteria."
5. That the Owner(s) enter into a Resurfacing Agreement with the City, to the satisfaction of the Program Manager, Right of Way Branch within the Planning, Development and Building Services Department, or their designate, and provide financial security in accordance with the Road Activity By-law, as amended, to install an asphalt overlay over the roadway surface of Hampton Ave, fronting the subject lands, to the limits shown on the approved Site Servicing Plan. Where the

approved Site Servicing Plan demonstrates the resurfacing is not required, based on the City's Road Cut Resurfacing Policy, the Manager of Development Review All Wards Branch within Planning, Development and Building Services Department, or their designate, shall deem this condition satisfied.

6. That the Owner/Applicant(s) enter into a Development Agreement or a Letter of Undertaking (LOU) with the City of Ottawa, at the expense of the Owner/Applicant(s), and to the satisfaction of the Manager of the relevant branch within Planning, Real Estate, and Economic Development Department, or their designate(s). A development agreement is to be registered on Title of the property (where applicable). The agreement will include the mitigation measures outlined in the approved Tree Information Report, prepared by IFS, dated Nov 27, 2024, and associated securities for tree protection. The securities, which will be based on the value of the tree(s) to be protected (Tree(s) 1) shall be retained for 2 years following issuance of an occupancy permit, and thereafter returned to the owner only upon the City having received a report from an arborist or appropriate professional confirming that the identified tree(s) is/are healthy, retainable, and remain(s) structurally stable. The Owner(s) acknowledge(s) and agree(s) that if, in the opinion of the City Forester and/or the Manager of the relevant Branch within Planning, Real Estate, and Economic Development, the report indicates that any tree is declining and/or must be removed, the Security for that tree, in its entirety, will be forfeited.
7. That the Owner/Applicant(s) provide a tree planting plan, prepared to the satisfaction of the Manager of the relevant Branch within the Planning, Real Estate and Economic Development Department, or their designate(s), showing the location(s) and species or ultimate size of at least one new tree (50 mm caliper) per lot, in addition to any compensation trees required under the Tree Protection By-law.



Penelope Horn
Planner I, Development Review All Wards
Planning, Development and Building
Services Department



Erin O'Connell
Planner III, Development Review All Wards
Planning, Development and Building
Services Department



110 Laurier Avenue West, Ottawa ON K1P 1J1 Mail code: 01-14
110, av. Laurier Ouest, Ottawa (Ontario) K1P 1J1 Courrier interne : 01-14

Visit us: Ottawa.ca/planning
Visitez-nous : Ottawa.ca/urbanisme