# **Committee of Adjustment** Received | Reçu le

2025-04-10

City of Ottawa | Ville d'Ottawa

This document is presented in the language it was provided. Ce document est présenté dans la langue dans laquelle il a été fourni.



MINOR VARIANCE APPLICATION Comité de dérogation NTS TO THE COMMITTEE OF ADJUSTMENT PANEL 1

## PLANNING, DEVELOPMENT AND BUILDING SERVICES DEPARTMENT

Site Address: 100 Hamilton Avenue North

Legal Description: Part of Lot 1354, Registered Plan 157

File No.: D08-02-25/A-00041

Report Date: April 10, 2025 Hearing Date: April 16, 2025 Planner: Dylan Geldart

Official Plan Designation: Inner Urban Transect, Neighborhood Designation, Evolving

Neighborhood Overlay

Zoning: R4UB

#### **DEPARTMENT COMMENTS**

The Planning, Development and Building Services Department has no concerns with the application.

#### **DISCUSSION AND RATIONALE**

Staff have reviewed the subject minor variance application against the "four tests" as outlined in Section 45 (1) of the Planning Act, R.S.O. 1990 c. P.13, as amended. Staff are satisfied the requested minor variances meet the "four tests".

### **ADDITIONAL COMMENTS**

#### Infrastructure Engineering

- The Planning, Development and Building Services Department will do a complete review of grading and servicing during the building permit process.
- At the time of building permit application, a grading/servicing plan prepared by a Professional Engineer, Ontario Land surveyor or a Certified Engineering Technologist will be required.
- Any proposed works to be located within the road allowance requires prior written approval from the Infrastructure Services Department.

- The surface storm water runoff including the roof water must be self-contained and directed to the City Right-of-Way, not onto abutting private properties as approved by Planning, Development and Building Services Department.
- Existing grading and drainage patterns must not be altered.
- Existing services are to be blanked at the owner's expense.
- Service lateral spacing shall be as specified in City of Ottawa Standard S11.3.
- In accordance with the Sewer Connection By-Law, a minimum spacing of 1.0m is required between service laterals and the foundation face.

### **Planning Forestry**

There are no concerns related to tree protection. A site visit revealed there are no trees protected under the City of Ottawa Tree Protection By-law (2020-340) on this property. There are also no adjacent city trees or trees greater than 30 cm on adjacent properties that will be impacted by the development.

The Owner is strongly encouraged to provide a planting plan with trees in the Right-of-Way and rear yard to improve both the canopy cover and streetscape following development to meet the City's 40% canopy goal.

## **Right of Way Management**

The Right-of-Way Management Department has no concerns with the proposed Minor Variance Application.

However, the Owner shall be made aware a Private Approach Permit is required to modify or close an existing entrance that becomes redundant. Please contact the Rightof-Way Department for further information at rowadmin@ottawa.ca.

Dylan Geldart Planner I, Development Review All Wards Planning, Development and Building Services Department

Erin O'Connell

Planner III, Development Review All Wards Planning, Development and Building Services Department

Lin Otmill