



**CONSENT & MINOR VARIANCE APPLICATION
COMMENTS TO THE COMMITTEE OF ADJUSTMENT
PANEL 2**

PLANNING, DEVELOPMENT AND BUILDING SERVICES DEPARTMENT

Site Address: 23 Palsen Street
Legal Description: Lot 35, Registered Plan 522
File No.: D08-01-25/B-00298, D08-01-25/B-00299, D08-02-25/A-00282, D08-02-25/A-00283
Report Date: January 29, 2026
Hearing Date: February 3, 2026
Planner: Dylan Geldart
Official Plan Designation: Outer Urban Transect, Neighborhood Designation
Zoning: R1FF

DEPARTMENT COMMENTS

The Planning, Development and Building Services Department **has no concerns with** the application.

DISCUSSION AND RATIONALE

Consent Application

Section 53 (12) of the Planning Act, R.S.O. 1990, c. P.13, as amended, permits the criteria for the subdivision of land listed in Section 51 (24) to be considered when determining whether provisional consent may be granted by a committee of adjustment. With respect to the criteria listed in Section 51 (24), staff have no concerns with the proposed consent.

Minor Variance Application

Staff have reviewed the subject minor variance application against the “four tests” as outlined in Section 45 (1) of the Planning Act, R.S.O. 1990 c. P.13, as amended. Staff are satisfied the requested minor variance meets the “four tests”.

ADDITIONAL COMMENTS

Infrastructure Engineering

- The Planning, Development and Building Services Department will do a complete review of grading and servicing during the building permit process.
- At the time of building permit application, a grading/servicing plan prepared by a Professional Engineer, Ontario Land surveyor or a Certified Engineering Technologist will be required.
- Existing grading and drainage patterns must not be altered.
- Existing services are to be blanked at the owner's expense.
- Asphalt overlay would be required if three or more road-cuts proposed on City Right of way. This includes the road cut for blanking of existing services, and any other required utility cuts (ie, gas, hydro, etc.).
- This property does not have frontage on a storm sewer.
- Service lateral spacing shall be as specified in City of Ottawa Standard S11.3.
- In accordance with the Sewer Connection By-Law a minimum spacing of 1.0m is required between service laterals and the foundation face.
- Encroachment on or alteration to any easement is not permitted without authorization from easement owner(s).

Planning Forestry

Through pre-consultation the site plans were modified to reduce impacts to protected trees. All existing trees on site are proposed for retention, with one new tree planted per lot to improve the canopy cover and streetscape of the site. There are no tree-related concerns with the requested variance or severance. Securities will be required to ensure the adequate protection of tree #1 through construction.

Right of Way Management

The Right-of-Way Management Department has no concerns with the proposed Consent and Minor Variance Applications. The Owner shall be made aware however, that a private approach permit is required to construct any new entrance, as well as to modify or close an existing entrance that becomes redundant. As a result of the proposed future development, two private approach permits will be required, (one for each newly constructed driveway). Please contact the ROW Department for any additional information at rowadmin@ottawa.ca or visit the City webpage [Driveways | City of Ottawa](https://ottawa.ca/en/urbanisme/transportation/Driveways) to submit a Private Approach application.

Transportation Engineering

Palsen Street along the site frontage is undergoing Storm Water Management Renewal

(Construction year, 2026). Construction coordination is required with the City of Ottawa Project Manager. Contact Kristyn Boehme (Kristyn.Boehme@ottawa.ca) to discuss construction plans and coordination.

CONDITIONS

If approved, the Planning, Development, and Building Services Department requests that the Committee of Adjustment impose the following conditions on the application:

1. That the Owner(s) provide evidence, to the satisfaction of the Manager of Development Review All Wards, Planning, Development and Building Services Department, that each existing parcel has its own independent storm, sanitary and water services connected to City infrastructure and that these services do not cross the proposed severance line. If they do cross or are not independent, the Owner(s) will be required, at their own cost, to relocate the existing services or construct new services from the City sewers/watermain. Notice shall be provided in writing to the Committee from the Department confirming this condition has been fulfilled.
2. That the Owner(s) provide a Stormwater Management Report, prepared by a Professional Civil Engineer, licensed in the Province of Ontario, demonstrating a design for post-development stormwater peak flows that are controlled to pre-development peak flows for all stormwater events up to and including the 100 year storm event. The report shall be to the satisfaction of and approved by the Manager of Development Review All Wards Branch within Planning, Development and Building Services Department, or their designate.

If the Stormwater Management Report includes infiltration techniques, the Owner(s) must provide a supporting Geotechnical Brief prepared by a Professional Civil Engineer licensed in the Province of Ontario, for approval by the Manager of Development Review All Wards Branch within Planning, Development and Building Services Department, or their designate

The Owner(s) shall enter into a Development Agreement with the City to construct the required stormwater system, which may include required securities. A copy of the Agreement and written confirmation from City Legal Services that it has been registered on title, shall be forwarded to the Committee of Adjustment.

If applicable, the Owner(s) shall obtain all necessary approvals from the Ontario Ministry of Environment, Conservation and Parks.

3. That the Owner(s) provide proof that a grading and drainage plan, prepared by a qualified Civil Engineer, licensed in the Province of Ontario, an Ontario Land Surveyor or a Certified Engineering Technologist, delineating the existing and proposed grades for both the severed and retained lands has been provided to the

satisfaction of the Manager of Development Review All Wards Branch within Planning, Development and Building Services Department, or their designate.

4. That the Owner(s) enter into a Resurfacing Agreement with the City, to the satisfaction of the Program Manager, Right of Way Branch within the Planning, Development and Building Services Department, or their designate, and provide financial security in accordance with the Road Activity By-law, as amended, to install an asphalt overlay over the roadway surface of Palsen Street, fronting the subject lands, to the limits shown on the approved Site Servicing Plan. Where the approved Site Servicing Plan demonstrates the resurfacing is not required, based on the City's Road Cut Resurfacing Policy, the Manager of Development Review All Wards Branch within Planning, Development and Building Services Department, or their designate, shall deem this condition satisfied.
5. That the Owner/Applicant(s) enter into a Development Agreement or a Letter of Undertaking (LOU) with the City of Ottawa, at the expense of the Owner/Applicant(s), and to the satisfaction of the Manager of Development Review All Wards Branch within Planning, Development and Building Services Department, or their designate. A development agreement is to be registered on title of the property (where applicable). The agreement/LOU will include the tree protection and mitigation requirements detailed in the Tree Protection By-law and the approved Tree Information Report (or any approved revisions), and associated securities for tree protection. The securities, which will be based on the value of the City tree(s) to be protected (Tree #1) shall be retained for two (2) years following issuance of a final occupancy permit, and thereafter returned to the owner only upon the City having received a report from an arborist confirming that the identified tree(s) is/are healthy, retainable, and remain(s) structurally stable. The Owner(s) acknowledges and agrees that if, in the opinion of the City Forester and/or the Manager of Development Review All Wards Branch, the report indicates that any tree is declining and/or must be removed, the security for that tree, in its entirety, will be forfeited.
6. That the Owner/Applicant(s) provide a Stormwater Management Plan with the proposed elements/structures (grading, retaining walls, stormwater structures, etc.) designed and located based on the least impact to protected trees and tree cover, as well as a revised Tree Information Report reflecting these changes to the satisfaction of the Manager of Development Review All Wards Branch within Planning, Development and Building Services Department, or their designate.



Dylan Geldart
Planner I, Development Review All Wards
Planning, Development and Building
Services Department



Erin O'Connell
Planner III, Development Review All Wards
Planning, Development and Building
Services Department