

# Appendix C

- Excerpts from the Gloucester and Cumberland East Urban Community Expansion Area and Bilberry Creek Industrial Park Master Servicing Update (Stantec, July 2006) (North Quadrants)... **C1-C2**
- Excerpts from the Servicing Report for Trails Edge and Orleans Business Park (DSEL, July 2017)... **C3-C9**
- Excerpts from the Design Brief for Caivan (Orleans Village) Limited – 3490 Innes Road (DSEL, May 2018)... **C10-C11**
- Excerpts from the Servicing and Stormwater Management Report – Orleans II Draft Plan of Subdivision (Stantec, April 12, 2018)... **C12-C13**
- Excerpts from the Servicing Options Report for Blacksheep Developments, 2159 Mer Bleue Road (DSEL, December 2017)... **C14-C15**
- Excerpts from the Gloucester and Cumberland East Urban Community Expansion Area and Bilberry Creek Industrial Park Master Servicing Update (Stantec, July 2006) (South West Quadrant)... **C16-C24**
- Excerpts from the Trails Edge East – Functional Servicing Report (Stantec, August 11, 2017)... **C25-C30**
- Excerpts from the Trails Edge East Phase 1 Servicing and Stormwater Management Report (Stantec, August 2018)... **C31-C32**
- Excerpts from the Design Brief for the Trails Edge West Richcraft Group of Companies (DSEL, January 26, 2015)... **C33-C35**
- Excerpts from the Mer Bleue Community Design Plan, Infrastructure Servicing Study (IBI Group, April 2006)... **C36-C43**
- Excerpts from the Orleans Family Health Hub Stormwater Management & Servicing Report (Exp., April 5, 2018)... **C44-C45**
- Excerpts from the Taggart Group of Companies Infrastructure Servicing Brief (Exp., November 20, 2013)... **C46-C47**





**GLOUCESTER AND CUMBERLAND  
EAST URBAN COMMUNITY  
EXPANSION AREA AND BILBERRY  
CREEK INDUSTRIAL PARK  
MASTER SERVICING UPDATE**

Prepared for:  
City of Ottawa

File No. 163400602  
November 2004  
Updated June 2005  
Updated October 2005  
Updated July 2006

Prepared by:  
Stantec Consulting Ltd.  
1505 Laperriere Avenue  
Ottawa, Ontario  
K1Z 7T1





- - - NEIGHBOURHOOD BOUNDARY
- - - EUC AREA BOUNDARY
- - - EXISTING WATERMAIN
- - - FUTURE WATERMAIN
- EXISTING ELEVATED STORAGE TANK
- FUTURE ELEVATED STORAGE TANK

**WATERMAINS**

FIRST SUBMISSION: FEB., 2004  
 REVISION No.: 5 JUNE, 2006



# **SERVICING REPORT**

*FOR*

## **TRAILS EDGE AND ORLEANS BUSINESS PARK**

### **MINTO DEVELOPMENTS INC. RICHCRAFT GROUP OF COMPANIES**

CITY OF OTTAWA

**PROJECT NO.: 10-459**

**JULY 2017  
REVISION 7  
© DSEL**

## 5.0 WATER SUPPLY SERVICING

### 5.1 Existing Water Supply Services

The Trails Edge Community and Orleans Business Park are situated within the City of Ottawa's water distribution Pressure Zone 2E. Within Pressure Zone 2E, an elevated storage tank on Innes Road (Innes EST) regulates hydraulic grade lines (HGLs) and balances peak demands.

There is an existing 600mm diameter transmission watermain along the Hydro Corridor, from Pagé Road to Mer Bleue Road, and an existing 400mm/600mm diameter watermain along Innes Road. There are also existing 300mm diameter watermain along Pagé Road and Renaud Road at the west and south ends of the development, and an existing 400 diameter watermain along Mer Bleue Road north of the Hydro One Corridor and south of Renaud Road. The approved *Gloucester and Cumberland EUC Expansion Area and Bilberry Creek Industrial Park Master Servicing Update* (Stantec, 2006) includes a planned 400m diameter watermain along Mer Bleue Road south of the Hydro One Corridor, to link these two feeder mains. The existing watermain are shown in **Figure 2**.

Within the study area, the approved *Gloucester and Cumberland EUC Expansion Area and Bilberry Creek Industrial Park Master Servicing Update* (Stantec, 2006) recommended a 400mm diameter watermain along Belcourt Extension to service the Orleans Business Park and Trails Edge Community. The analysis also recommended an internal network of 300mm watermain in the Orleans Business Park and a combination of 150mm, 200mm, and 300mm diameter watermain through the Trails Edge Community.

### 5.2 Proposed Water Supply

The proposed trunk water supply system has been updated from the *Gloucester and Cumberland EUC Expansion Area and Bilberry Creek Industrial Park Master Servicing Update* (Stantec, 2006) to reflect the updated road network and updated general demands generated from the projected land uses, as well as as-built information currently available.

A complete hydraulic analysis, named *Trails Edge Watermain Analysis* (Genivar, March 2014), was undertaken for the study area and is included in **Appendix G**. To size the main trunk watermain network, a water distribution model has been prepared for ultimate conditions using boundary conditions provided by the City of Ottawa for planning-level consumption rates.

The applicable *Water Distribution Guidelines* (City of Ottawa, July 2010) and recommended consumption rates (City of Ottawa Email Correspondence, January 2013) that were used in the design of the water distribution network are summarized in **Table 2**. The consumption rates differ from those presented in the *Water Distribution Guidelines* (City of Ottawa, July 2010), as the *Water Distribution Guidelines* are intended for the design for developments less than 50 ha in size.

**Table 2: Water Supply Design Criteria**

Design Parameter		Value
<b>Extracted from Section 4: Ottawa Design Guidelines, Water Distribution (July 2010)</b>		
Minimum Watermain Size		150 mm diameter
Service Lateral Size		19 mm diameter Soft Copper Type 'K'
Minimum Depth of Cover		2.4 m from top of watermain to finished grade
Desired Range of Operating Pressures		350 kPa and 480 kPa
Fire flow operating pressure minimum		140 kPa
<b>City of Ottawa – Email Correspondence with Mr. John Sevigny (January 2013)</b>		
Residential – Single Family	Average Day	570 L/unit/day
	Outdoor Water Demand	1050 L/unit/day
	Max Day	Average + OWD (L/unit/day)
	Peak Hour	1.5 x Avg Day + 2.1 x Max Day (L/unit/day)
Residential – Multi-Family	Average Day	560
	Outdoor Water Demand	0
	Max Day	Average (L/unit/day)
	Peak Hour	1.6 x Max Day (L/unit/day)
Residential - Apartment	Average Day	400 L/unit/day
	Outdoor Water Demand	0 L/unit/day
	Max Day	Average (L/unit/day)
	Peak Hour	1.6 x Max Day (L/unit/day)
Institutional / Commercial/ Industrial	Average Day	8500 L/ha/day
	Outdoor Water Demand	0 L/ha/day
	Max Day	Average (L/ha/day)
	Peak Hour	1.3 x Max Day (L/ha/day)
Total Average Day		Sum of Average Day for all land uses
Total Max Day		Sum Max Day for all land uses
Total Peak Hour		Sum of Peak Hour for all land uses
High Pressure Check		Minimum Hour = Average Day

The system-level unit demands and boundary conditions provided by the City were only for the purpose of sizing **major** watermains. As development proceeds, the City is expected to provide new boundary conditions for each phase of the development, to inform the detailed design of the different phases of the distribution network. Specifically, the local watermains shown in **Appendix G** will need to be re-analyzed and re-sized based on demands computed using the *Water Distribution Guidelines* (City of Ottawa, July 2010) and the associated new boundary conditions for each sub-area in the order of 50 ha or more. Note that although the trunk watermain alignment in the hydraulic model provided in **Appendix G** is consistent with the interim and ultimate land use plans (**Figure 3 & Figure 4**), the alignment of local watermains and land-use demands east of Belcourt Extension will also require updating as detailed design progresses for this area.

For the system-level analysis, fire flow requirements were taken as 100 L/s for detached single homes and 125 L/s for townhomes. The fire flows for commercial areas were taken as 217 L/s as per the *Gloucester EUC Infrastructure Servicing Study Update* (Stantec, 2006). A discussion on fire flow calculations is provided in **Appendix G**. An ordinary construction coefficient has been applied at the system-level for single homes and townhouses. At the detailed design level, the fire demand parameters to be used will be reviewed once unit types, architectural details (such as firewalls), and unit spacing are determined. Similar to the two-step process for unit demands, it is recommended that the local watermain network be re-analysed and re-sized according to detailed Fire Underwriter's Survey calculations as detailed design progresses for the site. It is not expected that this would impact the sizing of the major watermains system presented in this 2014 Servicing Report. **This statement is supported by the City of Ottawa Technical Bulletin ISDTB-2014-02 (May 27, 2014) which includes an interim qualification to the application of the FUS method, which may be used on an interim basis. Section 4 – 1 of Technical Bulletin ISDTB-2014-02 states the following:**

- **For single detached dwellings, the fire flow requirement may be capped at 10,000 L/min (167 L/s), provided that there is minimum separation of 10 metres between the backs of adjacent units.**

Based on the water distribution model, to meet maximum hour and maximum day plus fire flow demands, the proposed trunk watermain network is as follows:

- The Trails Edge Development will be connected to the existing watermains by a proposed 400mm diameter watermain along the Belcourt Extension. New 300mm diameter trunk watermains will be required to service the development, designed in accordance with the City of Ottawa and MOE Guidelines. The proposed watermain servicing layout for the Trails Edge Community is presented in **Figure 5**. The proposed watermain along Belcourt Extension will connect to the 600mm transmission watermain within the Hydro Corridor and the 300mm



diameter watermain on Renaud Road. In addition there are connections proposed to the Mer Bleue Road, Renaud Road, and Pagé Road watermains.

- The 400mm diameter watermain will be extended along the Belcourt Extension in the Orleans Business Park to Innes Road, as shown in **Figure 6**, and 300mm diameter watermains would serve the rest of the Business Park.


### 5.3 Water Supply Conclusion

The hydraulic analysis for the trunk watermains has been updated to reflect the updated road network, reflect the current water demands estimated for the projected populations/land uses, and to ensure compliance with the current *City of Ottawa Water Distribution Guidelines*, July 2010.

The watermain analysis indicates that the proposed trunk 300mm and 400mm diameter watermains satisfy the required demands. The service pressures are expected to range between 339 kPa and 469 kPa under the anticipated demand during average day, maximum hour and maximum day plus fire flow conditions, which is within the MOE and City of Ottawa required pressure range. The watermain concept is largely consistent with the *Gloucester and Cumberland EUC Expansion Area and Bilberry Creek Industrial Park Master Servicing Update* (Stantec, 2006).

The proposed major watermain network for the Trails Edge Development and Orleans Business Park can deliver all domestic and fire flows as per Ministry of the Environment, City of Ottawa and Fire Underwriters Criteria.

As noted in **Section 5.2**, at the time of local network design, additional detailed modeling will be required to reflect the proposed phasing plan and refined design demands and fire flow requirements. Specifically, additional modeling will be required east of Belcourt Extension to reflect the land use distribution that is pursued in detailed design.



DESIGN ALTERNATIVES TO BRING STORM DRAINAGE SYSTEMS NORTH OF THE HYDRO CORRIDOR TO MUNICIPAL STANDARDS ARE TO BE EVALUATED AS PART OF FUTURE STUDY (IN CONJUNCTION WITH COMMUNITY DESIGN PLAN). DESIGN OPTIONS FOR CONSIDERATION INCLUDE: DOING NOTHING; LIMITING RUNOFF FROM DEVELOPMENT AND MAINTAINING THE EXISTING POND; EXPANDING POND AND FOREBAY; AND BUILDING NEW POND.

AS DEFINED IN GLOUCESTER AND CUMBERLAND EAST URBAN COMMUNITY EXPANSION ARE AND BILBERRY CREEK INDUSTRIAL PARK MASTER SERVICING UPDATE BY STANTEC, 2006


- LEGEND**
- PROPOSED 3000 WATERMAIN
  - PROPOSED 4000 WATERMAIN
  - PROPOSED 6000 WATERMAIN
  - - - Ex. 3000 WATERMAIN
  - - - Ex. 4000 WATERMAIN
  - - - Ex. 6000 WATERMAIN
  - - - Ex. 9000 WATERMAIN



120 Iber Road, Unit 203  
 Stittsville, ON K2S 1E9  
 TEL: (613) 836-0856  
 FAX: (613) 836-7183  
 www.DSEL.ca

## ORLEANS BUSINESS PARK CONCEPTUAL WATERMAIN SERVICING

DATE:	FEBRUARY 2014
SCALE:	1:6000
PROJECT No.:	10-459
FIGURE	6



**LEGEND**

<span style="color: red;">—</span>	PROPOSED 3000 WATERMAIN
<span style="color: blue;">—</span>	PROPOSED 4000 WATERMAIN
<span style="color: magenta;">—</span>	PROPOSED 6000 WATERMAIN
<span style="color: red;">- - -</span>	Ex. 3000 WATERMAIN
<span style="color: blue;">- - -</span>	Ex. 4000 WATERMAIN
<span style="color: orange;">- - -</span>	Ex. 6000 WATERMAIN
<span style="color: cyan;">- - -</span>	Ex. 9000 WATERMAIN



120 Iber Road, Unit 203  
 Stittsville, ON K2S 1E9  
 TEL: (613) 836-0856  
 FAX: (613) 836-7183  
 www.DSEL.ca

# TRAILS EDGE

## CONCEPTUAL WATERMAIN SERVICING

DATE:	FEBRUARY 2014
SCALE:	1:6000
PROJECT No.:	10-459
FIGURE	C9 5

# DESIGN BRIEF



FOR

**CAIVAN (ORLEANS VILLAGE) LIMITED**  
**3490 INNES ROAD**

CITY OF OTTAWA

PROJECT NO.: 15-881


MAY 2018 – VER 2  
© DSEL



**NOTE:**  
 FUTURE ADJACENT ROAD NETWORK  
 AND ASSOCIATED TRUNK WATERMAIN  
 TO BE DETERMINED THROUGH THE  
 EAST URBAN COMMUNITY MIXED USE  
 CENTRE COMMUNITY DESIGN PLAN

**LEGEND:**

	SITE BOUNDARY
	PROPOSED 300Ø WATERMAIN
	PROPOSED 250Ø WATERMAIN
	PROPOSED 200Ø WATERMAIN
	PROPOSED 150Ø WATERMAIN
	Ex. 200Ø WATERMAIN
	Ex. 300Ø WATERMAIN
	Ex. 400Ø WATERMAIN
	Ex. 750Ø WATERMAIN
	Ex. 900Ø WATERMAIN



120 Iber Road, Unit 103  
 Stittsville, Ontario, K2S 1E9  
 Tel. (613) 836-0856  
 Fax. (613) 836-7183  
 www.DSEL.ca

**ORLEANS VILLAGE  
 WATER SERVICING**

CITY OF OTTAWA

PROJECT No.:	16-881
DATE:	MAY 2018
SCALE:	1:3000
FIGURE:	<b>C11</b>
	2

**Site Servicing and Stormwater  
Management Report –  
Orleans II Draft Plan of  
Subdivision**

Project # 160401419












Prepared for:  
Innes Shopping Centres Limited

Prepared by:  
Stantec Consulting Ltd.

April 12, 2018

Legend

-  406mm $\varnothing$  WATERMAIN
-  305mm $\varnothing$  WATERMAIN
-  203mm $\varnothing$  WATERMAIN
  
-  EX. 406mm $\varnothing$  WATERMAIN
-  EX. 305mm $\varnothing$  WATERMAIN
-  EX. 203mm $\varnothing$  WATERMAIN
  
-  FUT. 406mm $\varnothing$  WATERMAIN
-  FUT. 305mm $\varnothing$  WATERMAIN
-  FUT. 203mm $\varnothing$  WATERMAIN

Notes

1	ISSUED FOR DRAFT PLAN OF SUBDIVISION	DT	KS	18.04.11
Revision		By	Appd.	YY.MM.DD

File Name:	160401242-DB	DT	KS	DT	18.04.09
		Dwn.	Chkd.	Desgn.	YY.MM.DD


Permit-Seal

Client/Project  
INNES SHOPPING CENTRES LIMITED

ORLEANS II  
DRAFT PLAN OF SUBDIVISION  
Ottawa, ON


Title

OVERALL WATERMAIN LAYOUT

Project No.	Scale	0	10	30	50m
160401419	1:1000				

Drawing No.	Sheet	Revision
WM-1	3 of 4	1

WM-1 3 of 4 1  
C13



**SERVICING OPTIONS REPORT**

**FOR**


**BLACKSHEEP DEVELOPMENTS**  
**2159 MER-BLEUE ROAD**

CITY OF OTTAWA

PROJECT NO.: 17-934

DECEMBER 2017 – REV 2  
© DSEL





- NEIGHBOURHOOD BOUNDARY
- - - EUC AREA BOUNDARY
- 305 EXISTING WATERMAIN
- 405 FUTURE WATERMAIN
- EXISTING ELEVATED STORAGE TANK
- FUTURE ELEVATED STORAGE TANK

WATERMANS  
FIRST SUBMISSION: FEB., 2004  
REVISION No.: 5 JUNE, 2006

WM 4

**GLOUCESTER AND CUMBERLAND  
EAST URBAN COMMUNITY  
EXPANSION AREA AND BILBERRY  
CREEK INDUSTRIAL PARK  
MASTER SERVICING UPDATE**

Prepared for:  
City of Ottawa

File No. 163400602  
November 2004  
Updated June 2005  
Updated October 2005  
Updated July 2006

Prepared by:  
Stantec Consulting Ltd.  
1505 Laperriere Avenue  
Ottawa, Ontario  
K1Z 7T1



#### 4.1.5.1 Proposed Water System Network

The proposed EUC is currently fed by three existing large diameter watermains. These include a 406mm diameter main along Mer Bleue Drive along with two 305mm diameter watermains – one along Page Road and the other along Navan Road.

In order to assess the internal watermain requirements for the EUC, a hydraulic model was developed for the proposed road layout and land use. This was accomplished using a previous hydraulic model of the entire PZ 2E water distribution system. The model used for this exercise was the same model used in the 2004 HEPC analysis noted above, which was originally provided to Stantec by the City of Ottawa. The software used to carry out the analysis was H<sub>2</sub>OMAP by MWHSOft.

Modifications to the hydraulic model include the addition of internal network watermain throughout the proposed EUC. Nodes representing adjoining pipe lengths were inserted at intersections of watermain as well as along longer stretches of pipe. A higher density of nodes allows the modeler to be more detailed in the hydraulic analysis. **Figure 4-13** provides an overview of the watermain layout and diameters proposed for the EUC.


Watermain diameters were assigned in the internal network by first ensuring a strong transmission into the EUC. As noted previously, there are three existing feeds, two 305mm diameter watermain and a 406mm diameter watermain. The existing 203mm diameter watermain on Page Road north of Fourth Line Road and the 203mm diameter watermain west of Mer Bleue and south of Fourth Line Road were upgraded to 305mm diameter watermains. A fourth feed was added to the model along a proposed road that runs adjacent to the Innes Road EST and travels south over the HEPC into the EUC. With the feeds to the EUC established, watermains were sized to ensure good transmission throughout the EUC. As shown in **Figure 4-13**, several 305mm diameter watermains interconnect the four feeds coming into the EUC. These watermain provide a strong conveyance of peak flows and fire flows. They also ensure sufficient transmission should growth beyond the EUC occur in the future. In order to ensure sufficient fire flow capabilities at institutional and commercial facilities, a minimum of one 305mm diameter watermain was routed adjacent to these lands.

Within the localized neighborhoods, a combination of 203mm diameter watermain and 152mm diameter watermain were proposed. The smaller diameter watermains generally provide a limited amount of fire flow. However, due to their size, they reduce the amount of water retention in the pipe thereby helping to improve water quality. Various combinations of pipe diameters were considered prior to the final layout.

Once the internal pipe network was constructed within the model, elevations were added using a spatial join feature of H<sub>2</sub>OMAP. A digital elevation file was first brought into the model as a GIS layer and using the spatial join feature, elevations were assigned to every node in the model. The lowest ground elevations within the EUC (approximately 68m) are located in the southwest area of the EUC near Navan Road. The highest elevations (approximately 88m) are

located in the northeast area of the EUC near Mer Bleu Road. It is noted that a difference in elevation of 20m represents a difference of 30 psi (200 kPa) in the static pressures.


**Figure 4-13: Proposed Watermain Layout in EUC Expansion Area**



Controls at the two pumping stations were adjusted to ensure the fill and draw of the Innes Road EST between levels of 40% and 100% full. **Figure 4-14** shows how the Innes Road EST responded to maximum day flows with three-hour fires applied at periods when the tank reaches 40%. As indicated, the Innes Road EST was able to recover quickly following a fire event.

Roughness coefficients (“C” values) of 125 and 120 were used for larger and smaller watermains respectively. The larger watermains include diameters of 305mm and greater and the smaller include those smaller than 305mm in diameter.

**Figure 4-14: Percentage of Water in Innes Road EST During Hydraulic Analysis**



**4.1.5.1.1 Demand Allocation**

The residential, industrial, commercial and institutional (ICI) water demands were allocated using information from the sanitary sewer design tables and drawings. Demand nodes were created for each catchment area presented in the sewer design section. For each demand node, a demand was estimated for each of the four users (residential/ICI) within each catchment area.

For residential water demands, an average of 350Lpcd was applied to the population count for each demand node. A maximum day multiplier of 2.0 was used to establish the residential maximum day demand. The total residential population for the EUC (18,022) represents a demand of 12.6 ML/d fully developed.

To estimate the ICI flows, the gross area (ha) of land dedicated to each land use was summed for each demand node. For industrial flows, an average demand of 35,000 L/ha/d was applied to the gross area of industrial land at each demand node. The maximum day demand for industrial users is estimated at 1.5 the average demand. The total industrial maximum day demand was estimated to be 0.6 ML/d. For commercial and institutional flows, demands of 50,000 L/ha/d were applied to the gross area at each demand node for each land use. The total commercial and institutional maximum day demands were estimated to be 0.2M L/d and 2.0 ML/d respectively.


The total maximum day demand for the EUC is estimated to be 15.4 ML/d. Combined with the existing maximum day demand in Zone 2E, the total demand will just exceed the 2021 demand of 62 ML/d presented in the 2001 EUC Water Modeling report (assuming no water efficiency strategy).

#### 4.1.5.1.2 Hydraulic Analysis

With respect to storage capacity, the 2001 EUC Water Modeling Report states: "By 2021, the current storage in Zone 2E (4.5 ML Innes Road EST with 40% balancing storage) will be adequate to the year 2021 with a pumping rate of approximately 114 ML/d. The existing firm capacity of the Orleans and Forest Ridge Pumping Stations (with the largest single pump out at Forest Ridge PS only) is 117 ML/d. Thus the existing pumping/storage combination to Zone 2E appears to be adequate until approximately the year 2021."

In order to verify and assess the hydraulics of the proposed watermain layout, a set of fifteen representative nodes were selected for analysis. The locations of the observation nodes are shown in **Figure 4-15**.

Figure 4-15: Location of Observation Nodes in EUC Expansion Area




4.1.5.1.3 Average Day Demand Analysis

Under typical operating conditions, there is minimal headloss in the distribution system and therefore the pressures in the EUC will be dependant on ground elevations and hydraulic grade lines (HGLs) from the discharge of the pumping stations and the water levels in the Innes Road EST (which vary between 126m and 131m). The resulting average day pressures in the EUC vary between 50 psi and 90 psi, which are within the acceptable minimum and maximum pressure ranges (40 to 100 psi) recommended by the Ontario Ministry of the Environment and adopted by the City of Ottawa. The variations in pressures are due variations in HGLs as well variations in ground elevations, which range from (68m to 88m).

4.1.5.1.4 Peak Hour Demand Analysis

A peak hour demand analysis was carried out using an extended period simulation of maximum day demands. The diurnal patterns for residential and ICI demands were previously established in the City’s hydraulic model. **Figure 4-16** shows the resulting pressures that are anticipated under peak hour conditions. Similar to the average day results, the observed pressures vary within the acceptable range of 50 psi to 90 psi.

Figure 4-16: Resultant Pressures Under Maximum Day Diurnal Demand Conditions



4.1.5.1.5 Maximum Day Fire flow Analysis


A fire flow analysis was carried out for each observation node under maximum day demand conditions. In order to observe the dynamic interactions of the pumping stations and the elevated storage during fire flow conditions, a 3-hour fire flow was modeled during various periods of an extended period analysis. The fire flows were modeled between the 19:00 and 22:00 hours. The guidelines the City of Ottawa uses for ensuring adequate fire flows (for general areas) are 6,500 Lpm for residential areas and 13,000 Lpm for areas with ICI components. It is noted that for specific buildings, the Underwriters Fire Survey requires a determination of the fire suppression need based on parameters such as building material and size.

4.1.5.1.6 Residential Fire Flow Analysis

A series of runs were carried out with a 6,500Lpm fire flow demand allocated at each of the 15 individual observation nodes. The results of this analysis are presented in Figure 4-17. As shown, all nodes are capable of providing the 6500 Lpm fire flow with residual pressures greater than 20 psi (140kPa).



Figure 4-17: Maximum Day Demand Fire Flow Analysis Results at 6,500Lpm




4.1.5.1.7 ICI Fire Flow Analysis

A series of runs were carried out with a 13,000 Lpm fire flow demand allocated at each of the 15 individual observation nodes. The results of this analysis are presented in **Figure 4-18**. As shown, all but four nodes are capable of providing the 13,000 Lpm fire flow with residual pressures greater than 20 psi (140kPa). This is acceptable because the nodes that cannot provide the higher fire flow are located along residential watermains that do not require the higher fire flow.

In analyzing the results, it is noted that the four observation nodes that did not meet the minimum pressure requirement are located at points in the distribution system that are only fed by two 152mm diameter watermain as well as being in areas with ground elevation greater than 85m. Junctions that are fed by three 152mm diameter watermains in the higher elevations (i.e. Nodes 9 and 10) are capable of meeting the higher fire flow of 13,000 Lpm. (This depends on the lengths of feeds).

The fourth node that cannot meet the higher ICI fire flow is Node 15 located in a residential area south of Navan Road. This node is serviced by a 305mm diameter feed that is connected to a 203mm diameter loop. The elevation of 84m is in the higher range of elevations.

Figure 4-18: Maximum Day Demand Fire Flow Analysis Results at 13,000 Lpm



4.1.5.1.8 Recommendations

The proposed network of large and small diameter watermains shown in **Figure 4-13** will be capable of providing the residential and ICI demands under average day, peak hour and fire flow conditions within the recommended minimum and maximum pressure ranges. Those areas designated as residential will meet (at minimum) the 6,500 Lpm fire flow requirements and those areas designated as ICI will meet (at minimum) the 13,000 Lpm fire flow requirements.

It is important to note that any future modifications to the proposed network consider higher fire flow needs of ICI areas as well as the constraints that the higher elevations in the expansion area may pose on the ability to meet the higher fire flow requirements.

## **Trails Edge East – Functional Servicing Report**

Project #160401250



Prepared for:  
Richcraft Group of Companies

Prepared by:  
Stantec Consulting Ltd.

August 11, 2017

### 3.0 POTABLE WATER ANALYSIS

#### 3.1 BACKGROUND

The proposed development is located within Zone 2E of the City of Ottawa's water distribution system. This zone is fed by the Forest Ridge Pump Station, with the Innes Road elevated storage tank providing balancing storage for peak flows and demands.

A 300mm diameter watermain exists along Renaud Road immediately south of the Trails Edge Development area, and a 400mm diameter main exists along Mer Bleue Road between Renaud Road and Brian Coburn Boulevard, and north of the Hydro One Corridor (HEPC). 400mm and 600mm watermains exist further north along Innes Road. A 600mm watermain exists at the northern boundary of the site along the HEPC.

#### 3.2 PROPOSED WATERMAIN SIZING AND LAYOUT

The proposed watermain alignment and sizing for this development is shown on **Drawing WTR-1** with 203mm diameter and 305mm diameter piping. It should be noted that the pipe layout and sizing for the development is preliminary, and is to be verified upon detailed hydraulic analysis for the development area.

##### 3.2.1 Ground Elevations

The proposed ground elevations of the development range from approximately 87.36m to 89.37m. Preliminary grading and elevations have been determined for the site and included on **Drawing GP-1**.

##### 3.2.2 Water Demand

The current draft plan for the Trails Edge East Development calls for a total of 250 single units, 816 townhouse units, and an estimated population of 3,053 persons. An additional 32.12ha of future mixed-use development is expected to contribute to overall demands from the existing watermains at the northern boundary of the development.

Water demands for the development were estimated using the City of Ottawa's Water Distribution Design Guidelines. For residential developments, the average day (AVDY) per capita water demand is 350 L/cap/d. For maximum day (MXDY) demand, AVDY was multiplied by a factor of 2.5 and for peak hour (PKHR) demand, MXDY was multiplied by a factor of 2.2. For commercial and institutional use, the AVDY is based on the area of land use and is shown in the following tables. For MXDY demand, AVDY was multiplied by a factor of 1.5 and for PKHR demand, MXDY was multiplied by a factor of 1.8. The calculated residential water consumption

## TRAILS EDGE EAST – FUNCTIONAL SERVICING REPORT

Potable Water Analysis  
August 11, 2017

and future mixed use (area identified as MUC within the EUC Master Servicing Update) water consumption is represented in **Table 1** and **Table 2** for the Trails Edge East development:

**Table 1: Residential Water Demands**

Unit Type	Units	Person/Unit	Population	AVDY (L/s)	MXDY (L/s)	PKHR (L/s)
Singles	250	3.4	850.0	3.44	8.61	18.94
Townhomes	816	2.7	2203.2	8.93	22.31	49.09
		Total	3053.2	12.37	30.92	68.03

**Table 2: Mixed Use Area (MUC) Water Demands**

Area (ha)	Population	AVDY (L/s)	MXDY (L/s)	PKHR (L/s)
32.12	1526	6.18	15.45	34.00

### 3.2.3 Connection to Existing Infrastructure

Potable water supply will be connected to the existing watermains located on Mer Bleue Road, Renaud Road, and Belcourt Boulevard. **Drawing WTR-1** shows the location of the connection points to the existing watermains.

It is anticipated that the development will be phased from west to east. A minimum of two connections to the surrounding 300mm and 400mm watermains will be provided as development proceeds to the west, with no more than 49 units serviced on a temporary basis via single feed per City guidelines.

## 3.3 HYDRAULIC ASSESSMENT

A hydraulic model was built by Stantec for the Zone 2E Watermain Extension (HEPC) Analysis in June 2004, and later revised for the EUC Master Servicing Update in July 2006. The model assumes a single proposed 300mm main bisecting the Trails Edge East development, along with existing 400mm mains within Mer Bleue, Renaud Road, and Belcourt Boulevard. It is of note that the majority of internal watermains to the Trails Edge East development were considered as being of 150mm in diameter. Stantec assessed the anticipated pressures in this development at full buildout to meet minimum servicing requirements (basic day and peak hour demands). A fire flow analysis was also performed under maximum day conditions (see **Appendix A** for excerpts). Additionally, DSEL/IBI Group completed individual hydraulic analyses to demonstrate available fire flow capacity within the adjacent Trails Edge West development areas west of Belcourt Boulevard during early 2015.

## TRAILS EDGE EAST – FUNCTIONAL SERVICING REPORT

Potable Water Analysis  
August 11, 2017

### 3.3.1 Allowable Pressures

The City of Ottawa Water Distribution Design Guidelines state that the desired range of system pressures under normal demand conditions (i.e. basic day, maximum day, and peak hour) should be in the range of 350 to 552 kPa (50 to 80 psi) and no less than 275kPa (40 psi) at the ground elevation in the streets (i.e. at hydrant level). The maximum pressure at any point in the distribution system is to be no higher than 552kPa (80 psi). As per the Ontario Building Code & Guide for Plumbing, if pressures greater than 552kPa (80 psi) are anticipated, pressure relief measures are required. Under emergency fire flow conditions, the minimum pressure in the distribution system is allowed to drop to 138kPa (20 psi).

### 3.3.2 Fire Flow

The Master Servicing Update model assessed a maximum fire flow of 13,000 L/min for EUC area based on Fire Underwriters Survey (FUS) requirements, and used a minimum requirement of 6,500L/min for residential areas where the 13,000 L/min target could not be achieved.

It should be noted that as per the City's most recent technical bulletin in regards to fire flow (ISDTB-2014-02) for traditional side-by-side towns and row houses constructed in accordance with the OBC, the fire flow requirement shall be capped at 10,000 L/min. As such, nodes that are able to meet the 13,000 L/min fire flow are expected to perform adequately for the proposed development.

Three nodes within the 2006 model are noted as lying within the Trails Edge East development area; nodes 10, 11 and 12. Of these, node 11 was unable to meet the 13,000 L/min target. It was noted in the June 2004 HEPC Analysis report that this was largely due to the model's assumption of two 150mm mains serving that particular node, while nodes 10 and 12 were to maintain three 150mm watermain connections. It is assumed that upgrading internal watermain links to 200mm in diameter will be sufficient to address fire flow requirements for the development area.

Fire flow assessment will be required at the subdivision approval phase in which local watermains are checked for their ability to provide the objective FUS fire flows, which in turn will be determined based on final unit layouts. Smaller, local internal watermains will need to be assessed and verified as development planning proceeds.

## TRAILS EDGE EAST – FUNCTIONAL SERVICING REPORT

Potable Water Analysis  
August 11, 2017

### 3.4 POTABLE WATER SUMMARY

The proposed piping alignment and sizing is capable of achieving the level of service in the Richcraft subdivision. Based on the hydraulic analysis created at the Master Servicing level, the following conclusions were made:

- The proposed water distribution system is recommended to include a combination of 305mm and 203mm diameter pipes;
- During peak hour conditions, the proposed system is capable of operating above the minimum pressure objective of 276kPa (40psi);
- During fire conditions, the proposed system is capable of providing sufficient fire flows (13,000L/min and above) while maintaining a residual pressure of 138kPa (20 psi) in the majority of the Trails Edge East development. Sizing of internal mains on local streets will be coordinated to ensure a minimum fire flow of 10,000 L/min may be achieved.

Legend

	406mm $\varnothing$ WATERMAIN
	305mm $\varnothing$ WATERMAIN
	203mm $\varnothing$ WATERMAIN
	152mm $\varnothing$ WATERMAIN
	EX. 406mm $\varnothing$ WATERMAIN
	EX. 305mm $\varnothing$ WATERMAIN
	EX. 203mm $\varnothing$ WATERMAIN
	EX. 152mm $\varnothing$ WATERMAIN

Notes

Revision	Description	By	Appd.	Date
2	DRAFT PLAN APPROVAL 2ND SUBMISSION	MJS	SG	17.08.11
1	DRAFT PLAN APPROVAL 1ST SUBMISSION	MJS	SG	16.11.02

File Name:	16401250.MSS	MJS	SG	MJS	16.10.06
		Dwn.	Chkd.	Dign.	YY:MM:DD

Permit-Seal



Client/Project

RICHCRAFT GROUP OF COMPANIES  
2280 ST. LAURENT BLVD  
OTTAWA, ON, K1G 4K1  
TRAILSEGE EAST SUBDIVISION

Title

OVERALL WATERMAIN SYSTEM

Project No.  
164041250



Drawing No.

Sheet **C30** Revision

WTR-1

3 of 5

2



W:\clients\16401250\16401250-Overall Watermain System.dwg  
 20/10/11 10:47:57 AM  
 ORIGINAL SHEET - ARCH-D





## **Trails Edge East Phase 1**

Servicing and Stormwater Management  
Report

Project # 160401250

August 23, 2018

Prepared for:

Richcraft Group of Companies

Prepared by:

Stantec Consulting Ltd.

Copyright Reserved

The Contractor shall verify and be responsible for all dimensions. DO NOT scale the drawing - any errors or omissions shall be reported to Stantec without delay.  
The Copyrights to all designs and drawings are the property of Stantec. Reproduction or use for any purpose other than that authorized by Stantec is forbidden.

Legend

- PROPOSED WATERMAIN
- PROPOSED VALVE AND VALVE BOX
- PROPOSED VALVE CHAMBER
- PROPOSED REDUCER
- PROPOSED FIRE HYDRANT
- PROPOSED SANITARY SEWER
- PROPOSED STORM SEWER
- PROPOSED CATCHBASIN MANHOLE
- PROPOSED CATCHBASIN
- PROPOSED SUBDRAIN CATCHBASIN
- EXISTING WATERMAIN
- EXISTING VALVE AND VALVE BOX
- EXISTING VALVE CHAMBER
- EXISTING REDUCER
- EXISTING FIRE HYDRANT
- EXISTING SANITARY SEWER
- EXISTING STORM SEWER
- EXISTING CATCHBASIN MANHOLE
- EXISTING CATCHBASIN
- EXISTING SUBDRAIN CATCHBASIN
- FUTURE WATERMAIN
- FUTURE VALVE AND VALVE BOX
- FUTURE VALVE CHAMBER
- FUTURE REDUCER
- FUTURE FIRE HYDRANT
- FUTURE SANITARY SEWER
- FUTURE STORM SEWER
- FUTURE CATCHBASIN MANHOLE
- FUTURE CATCHBASIN
- FUTURE SUBDRAIN CATCHBASIN
- IPEX ICD TYPE AS NOTED OR EQUIVALENT
- HYDROVEC ICD OR EQUIVALENT (SEE DWG SD-1)
- CIRCULAR ORIFICE (SEE DWG SD-1)
- CATCHBASINS TO BE INTERCONNECTED
- PROPOSED DEPRESSIONED CURB LOCATIONS
- PROPOSED MOUNTABLE/BARRIER CURB LOCATION
- SERVICE LATERAL LOCATION (SANITARY, STORM AND WATER), SEE DRAWING DS-1 FOR TYPICAL SERVING LATERAL LOCATIONS.
- TACTILE WALKING SURFACE INDICATOR
- PHASING LINES

Notes

- 2 REVISED AS PER CITY COMMENTS AND DRAFT PLAN MJS DT 18.08.23
- 1 REVISED AS PER CITY COMMENTS MJS DT 18.05.30
- 0 ISSUED TO CITY FOR REVIEW MJS DT 18.03.06

Revision	By	Appd.	Y.M.M.D.D
2	MJS	DT	18.08.23
1	MJS	DT	18.05.30
0	MJS	DT	18.03.06

File Name:	MJS	MJS	MJS	18.02.14
Permit/Seal	Dwn.	Chkd.	Dsgn.	Y.M.M.D.D
160401250 OSSP.DWG				

Client/Project	Richcraft Group of Companies
2280 ST. LAURENT BLVD OTTAWA, ON, K1G 4K1	
TRAILSEDGE EAST SUBDIVISION OTTAWA, ON, CANADA	

Title	Overall Site Servicing Plan
Project No.	160401250
Drawing No.	OSSP-1

Scale	1:1250
Sheet	2 of 44
Revision	3

Scale	0 12.5 37.5 62.5m
Sheet	2 of 44
Revision	3

Scale	0 12.5 37.5 62.5m
Sheet	2 of 44
Revision	3


Scale	0 12.5 37.5 62.5m
Sheet	2 of 44
Revision	3

Scale	0 12.5 37.5 62.5m
Sheet	2 of 44
Revision	3

Scale	0 12.5 37.5 62.5m
Sheet	2 of 44
Revision	3

Scale	0 12.5 37.5 62.5m
Sheet	2 of 44
Revision	3

Scale	0 12.5 37.5 62.5m
Sheet	2 of 44
Revision	3



W:\projects\160401250\_TrailsEdge East\Design\Drawings\160401250\_OSSP.dwg  
2018/08/23 1:54 PM by: Chk. J.Richcraft

**DESIGN BRIEF**

*FOR THE*


**TRAILS EDGE WEST**

**RICHCRAFT GROUP OF COMPANIES**

CITY OF OTTAWA

**PROJECT NO.: 12-612**

**JANUARY 26, 2015**  
**REVISION 3, 3<sup>RD</sup> SUBMISSION**  
**© DSEL**



- LEGEND**
- STORM MANHOLE
  - SANITARY MANHOLE
  - STORM MANHOLE IN OTHER PHASES
  - SANITARY MANHOLE IN OTHER PHASES
  - RLCSB - ELBOW SECTION (CITY STD. S31) / T SECTION (CITY STD. S30), AS NOTED ON THE DRAWING
  - SINGLE STORM HOUSE CONNECTION
  - SINGLE SANITARY HOUSE CONNECTION
  - SINGLE WATER CONNECTION
  - HYDRANT
  - TEE
  - VALVE & BOX
  - VALVE & CHAMBER
  - SINGLE/DOUBLE CATCHBASIN
  - CATCHBASINS WITH INLET CONTROL
  - DEVICE IPEX TEMPEST A (Q max = 19.9 l/s)
  - CATCHBASINS WITH INLET CONTROL
  - DEVICE IPEX TEMPEST B (Q max = 28.4 l/s)
  - CATCHBASINS WITH INLET CONTROL
  - DEVICE IPEX TEMPEST C (Q max = 35.5 l/s)
  - CATCHBASINS WITH INLET CONTROL
  - DEVICE IPEX TEMPEST D (Q max = 50.1 l/s)
  - CATCHBASINS WITH INLET CONTROL
  - DEVICE IPEX TEMPEST E (Q max = 69.1 l/s)
  - BARRIER CURB (STD. SC1.1) WITH DEPRESSION SECTION
  - MOUNTABLE CURB (STD. SC1.3)
  - PHASE LINE
  - OVERLAND FLOW DIRECTION
  - EXTERNAL OVERLAND FLOW DIRECTION
  - 1.5m HIGH BLACK VINYL CHAIN LINK FENCE
  - 3.0m HIGH WOOD ACOUSTIC FENCE (SEE LANDSCAPE DWG. FOR DETAILS)
  - 250# PERFORATED PIPE (REFER TO CITY STD'S S29, S30 FOR REAR YARD TRENCH AND PIPE DETAILS ONLY)
  - BUILDING ENVELOPE
  - THERMAL INSULATION AS PER CITY OF OTTAWA STD. W22
  - TRANSFORMER

REFER TO DWG No. 6

**TOPOGRAPHIC INFORMATION**  
 TOPOGRAPHIC INFORMATION PROVIDED BY STANTEC GEOMATICS LIMITED, FILE No. 161611903-111, SURVEY DATED AUGUST 2, 2012.

**LEGAL INFORMATION**  
 CALCULATED M-PLAN PROVIDED BY STANTEC GEOMATICS LIMITED, JOB No. 161613137-132, RECEIVED ON MARCH 28, 2014.  
 1st RE-SUBMISSION 14-05-16

**NOT FOR CONSTRUCTION**

**ELEVATION NOTE** ELEVATION = 86.708 m

ELEVATIONS ARE GEODETIC AND ARE DERIVED FROM NATIONAL CAPITAL COMMISSION No. 019680227, HAVING AN ELEVATION OF 86.708 m.

No.	BY	DATE	DESCRIPTION	BY
2	Z.L.	14-05-16	1st RE-SUBMISSION	
1	Z.L.	12-09-14	1st SUBMISSION	

**Ottawa CITY OF OTTAWA**

PROJECT No. 12-612

**GENERAL PLAN** © DSEL

**RICHCRAFT GROUP OF COMPANIES**

**TRAILS EDGE WEST**

**DSEL**  
david schaeffer engineering ltd

120 Ier Road, Unit 203  
 Stittville, ON K2S 1E9  
 Tel: (613) 836-0856  
 Fax: (613) 836-7183  
 www.DSEL.ca

DRAWN BY: W.L./C.M. CHECKED BY: K.M. DRAWING NO. SHEET NO.  
 DESIGNED BY: K.M. CHECKED BY: Z.L.  
 SCALE: 1:1000 DATE: SEPTEMBER 2012 **5**

MUD CREEK UPGRADES  
 REFER TO  
 DAVID SCHAEFFER ENGINEERING LIMITED  
 PROJECT No. 12-613

ANY DISTURBED AREA DURING CONSTRUCTION TO BE RESTORED TO THE ORIGINAL CONDITION OR BETTER TO THE SATISFACTION OF THE AUTHORITIES HAVING JURISDICTION

PERMISSION REQUIRED FOR WORK ON ADJACENT LANDS

CONTRACTOR TO VERIFY THE PRECISE LOCATIONS AND INVERT ELEVATIONS OF EX. UNDERGROUND SERVICES AND EX. UTILITIES PRIOR TO STARTING CONSTRUCTION

**NOTE:**  
 ALL EXISTING POST & WIRE FENCE WITHIN LOTS, BLOCKS AND PROPOSED ROW TO BE REMOVED, WHERE APPLICABLE

**NOTE:**  
 ALL EXISTING FENCE AND CULVERTS WITHIN LOTS, BLOCKS AND PROPOSED ROW TO BE REMOVED, WHERE APPLICABLE


REFER TO DWG No. 6

**NOTE RE: WATERMAIN / WATER SERVICE**

- INSULATION REQUIRED FOR WATERMAIN / WATER SERVICE WHERE THE SEPARATION BETWEEN WATERMAIN / WATER SERVICE AND OTHER SERVICES AND STRUCTURES IS LESS THAN 1.2m AND THE COVER IS LESS THAN 2.4m. REFER TO CITY STD. W23 FOR DETAIL.
- FOR SERVICE INSTALLATION AT SEWER CROSSING, REFER TO CITY STD. W38 FOR DETAIL.

**NOTE**  
 FOR WATERMAIN CROSSING BELOW AND ABOVE SEWERS, REFER TO CITY STD. W25 AND W25.2, RESPECTIVELY, WHERE APPLICABLE.

**NOTE**  
 FOR WATERMAIN STUBS, 2.4m MIN. COVER TO BE PROVIDED





## MER BLEUE COMMUNITY DESIGN PLAN INFRASTRUCTURE SERVICING STUDY

---

Prepared for  
C. FLEMING DEVELOPMENTS, TAGGART REALTY,  
AND MINTO DEVELOPMENTS

3546-LD  
APRIL, 2006



C36



---

**Stantec**

March 15, 2006  
File: 163400620

IBI Group  
1770 Woodward Drive,  
Ottawa, Ont.  
K2C 0P8

**Attention: Bob Wingate, P. Eng.**

Dear Mr. Wingate:

**Reference: Mer Bleue Community Design Plan – Potable Water Hydraulic Analysis**

Stantec Consulting Ltd. (Stantec) is pleased to provide the following analysis of the proposed water distribution system in the Mer Bleue Community (MBC), previously referred to as Neighborhood N5 of the East Urban Community (EUC), located in the east end of the City of Ottawa (City) and south of Innes Road. The focus area of this analysis is situated between Mer Bleu Rd. and Tenth Line just south of the hydro easement corridor.

#### Past Studies

In recent years, Stantec has carried out several hydraulic capacity studies of the City's Pressure Zone 2E (PZ 2E). The following summarizes the findings related to the proposed MBC.

In June 2004, at the request of the City, Stantec carried out a hydraulic analysis for the proposed large diameter transmission watermain proposed along the Hydro Easement Power Corridor (HEPC). The conclusion of that report was that a smaller diameter watermain would be sufficient to meet the City's infrastructure needs. The recommended diameter for the proposed HEPC watermain was reduced from 762mm to a combination of 610mm and 406mm diameter watermain.

In December 2004, Stantec Consulting Ltd. prepared a technical memorandum for CCL Ltd. that presented a preliminary hydraulic analysis for the EUC Neighborhood #5. That memo concluded that the existing water distribution system in PZ 2E along with the proposed piping infrastructure would be capable of servicing the proposed growth. This current study provides additional analysis for the latest land use and population projections for the proposed MBC.

**Reference: Mer Bleue Community Design Plan – Potable Water Hydraulic Analysis**

The most recent technical document that Stantec prepared for the City for this general area is the October 24, 2005 memo to Mike Wildman of the City entitled “East Urban Watermain Staging and Timing”. The memo reviews two specific PZ 2E components including the PZ 2E HEPC watermain sizing, timing and alignment as well as the St Joseph Blvd/Trim Road watermain timing. Although both components are important to the future expansion of PZ 2E, the timing and alignment of the proposed HEPC watermain may have an impact on the proposed Mer Bleue development. In the October 2005 memo to the City, Stantec Consulting Ltd. concluded that based on existing system conditions and reliability requirements, a significant cost savings to the City could be realized by relocating a section of the proposed 406mm diameter HEPC watermain through Neighborhood #5 (now MBC) without impacting the service level or the system reliability needs.

Background

The major water supply infrastructure needs for the MBC will follow the current City of Ottawa guidelines and standards. These include the need for provision of minimum pressures during peak demand periods (maximum demand in a summer day), adequate fire protection, appropriate system redundancy and looping, consideration of water quality in the distribution system and of future development.

The entire MBC lies within Zone 2E of the City’s water distribution system. This zone is currently fed by two separate booster-pumping stations (which are fed directly from Zone 1E) and is considered “open” as the Innes Road Elevated Water Storage Tank regulates the pressure in this zone. The tank normally operates at a hydraulic grade line (HGL) between approximately 126m and 130m. With typical ground elevations in the MBC of approximately 88m, the average day pressure, assuming minimal headloss, would vary between **370 kPa (54psi) and 410Pa (60 psi)**.

Under peak demand conditions, the minimum design pressure (per City standards) is **275kPa (40 psi)**, although a higher value of 345kPa (50 psi) is preferred. Under fire flow conditions; the minimum pressure (per City standards) is **140kPa (20 psi)**.

Building-specific fireflow requirements are determined based on building type, material, spacing to adjacent structure, etc. For planning purposes, fireflows of **6,500L/min** for residential areas and **13,000L/min** for commercial and institutional lands are generally considered adequate.

System redundancy is an important part of the water distribution system as it ensures water service in the event of a break or outage of a major system component. For areas such as the MBC, this will require that “looped” watermain networks be used. Looped systems also have the benefit of minimizing long lengths of dead-end watermains, which assist in ensuring



**Reference: Mer Bleue Community Design Plan – Potable Water Hydraulic Analysis**

movement of water within the pipe and thus avoids stagnation. By maximizing water movement, water quality is maintained in the system extremities. Looped systems of larger watermains should also be considered where future growth might require the capacity afforded by larger watermains.

Existing Water System Network

In general terms, the existing distribution system in PZ 2E is considered robust. There is a strong network of 610mm and 406mm diameter watermains east of the existing Innes Road Elevated Water Storage Tank. Initially, the major feeds to the Mer Bleue Community (Phase 1) will be through the existing 610mm on Innes Road, which feeds a newly constructed 406mm diameter watermain along Tenth Line to Lakepointe St. The second feed to the MBC will be through an existing 305mm diameter watermain along the proposed Blackburn Hamlet Bypass. Additional feeds will be provided by future connections to watermain in the Avalon South development located just east of the proposed MBC. As well, connections along Mer Bleue to the future HEPC large diameter trunk watermain in the north and to the distribution network in the south will further strengthen the supply to the community.

The proposed diameters and layout of watermain in and around the MBC are shown in **Figure 1**. The hydraulic analysis considered two phases; Phase 1 includes only two feeds (a 406mm and a 305mm diameter) to the MBC as shown in **Figure 2**. For the purpose of this study, the second phase, labeled build-out includes an additional two feeds to the Avalon South Community as shown in **Figure 3**. The build-out model did not include the connections along Mer Bleue as the timing of these developments is unknown at this time. Furthermore, the initial modeling exercise did not consider upsizing the existing 152mm diameter watermain along Tenth Line between Lakepointe St and the Blackburn Bypass, however the results demonstrate why this should be considered.

Hydraulic Analysis

The hydraulic modeling exercise was carried out using a complete-pipe hydraulic model for PZ 2E. The software package used was H2OMap Water by MWHSOFT. The model, originally provided to Stantec by the City was modified to include future proposed developments in Avalon South and the Gloucester EUC. Larger diameter trunk watermains 305mm diameter and larger were placed in the MBC to ensure appropriate loping and servicing to all areas. Smaller diameter watermains to individual developments within the MBC were not included in this analysis. The sizing of internal watermains in MBC will be carried out at a later date.

Water demands in MBC were estimated using population figures and land use areas provided by IBI Group. Typical consumption and household sizes were assumed in order to determine an overall demand. **Table 1** provides the estimation of overall demands for the MBC. The total

**Reference: Mer Bleue Community Design Plan – Potable Water Hydraulic Analysis**

demands in **Table 1** were then distributed to 36 nodes within the MBC. Sufficient nodes were added to the trunk lines in the model to ensure a good distribution of demands.

In order to determine the trunk watermain requirements for the MBC, four hydraulic conditions were modeled for the MBC water distribution analysis. They include:

- 1) Basic Day (BSDY) – Extended Period Simulation (EPS) analysis to determine typical pressures (usually helps to identify high pressure as well as water quality concerns).
- 2) Maximum Day (MXDY) + Fire – Steady State analysis to determine available flows (at minimum pressures) for Phase 1 and Build-Out.
- 3) Peak Hour (PKHR) – MXDY EPS analysis to determine typical pressures under peak (non-emergency) demands.
- 4) Reliability – BSDY + Fire + break in distribution system analysis to determine if sufficient fireflows can be provided under an emergency watermain break condition.

Basic Day (BSDY)

The BSDY diurnal analysis provides anticipated pressures under typical demand conditions. Under this demand condition, headlosses in the distribution system are minimal and therefore if there was a low ground elevation constraint high pressures might be experienced. However as stated in the background, elevations in the MBC lands are generally flat in the 88m above datum range and the resulting BSDY pressures vary between **370 kPa (54psi) and 410Pa (60 psi)** as the water level fluctuates in the Innes Road Elevated Water Storage Tank. These pressures are within the preferred pressure range of 345 kPa (50psi) to 550 kPa (80 psi). Therefore no additional measures are needed to address BSDY needs.

Maximum Day (MXDY) + Fire

The MXDY + Fire steady state analysis provides an indication as to the amount of water that will be available under a fire condition. Water distribution systems are designed to provide fireflows under maximum day demand conditions. The Fire Underwriters Survey usually establishes the required fire flow for specific buildings types. However when multi-use communities are being planned for, the City typically allows rule of thumb guidelines to be used. For example, in order to provide a suitable fireflow that meets most residential requirements, it is proposed that a minimum of **6500Lpm** be provided under MXDY demand conditions, whereas in order to provide a suitable fireflow that meets Industrial, Commercial and Institutional (ICI) requirements, a minimum of **13,000Lpm** should be provided under MXDY demand conditions.

**Reference: Mer Bleue Community Design Plan – Potable Water Hydraulic Analysis**

Two scenarios were modeled for the MXDY + Fire condition, Phase 1 and Build-out. The Phase 1 scenario considers only two feeds to the MBC, one at Lakepointe and one at the Blackburn Bypass. It is anticipated, as shown in **Figure 4**, that all areas of the MBC will be provided with at least **13,000Lpm** of MXDY fireflow along the trunk watermains with the exception of locations along Tenth Line. The existing 152mm diameter watermain along Tenth Line restricts the flow significantly in this area; as such resulting fireflows at certain locations along Tenth Line may only reach **6500Lpm**. Considering that there is future commercial development proposed along Tenth Line there may be a requirement to upgrade the Tenth Line watermain to a larger diameter in order to provide the appropriate fireflows.

The second scenario modeled (build-out) was identical to the Phase 1 scenario with the exception that two additional feeds from Avalon South were opened. (The feeds along Mer Bleue remained closed). As shown in **Figure 5**, the additional feeds from Avalon South significantly increase the available flows in the southern portion of MBC. It is noted however that even with the additional feeds, the flows along the small diameter watermain on Tenth Line remain as low as **6500Lpm**.

Peak Hour (PKHR)

**Figure 6** shows that under the peak hour demand conditions for Phase 1, the minimum pressures in the MBC distribution system along the large diameter trunk watermain are anticipated to be approximately 50 psi (345 kPa). **Figure 7** shows similar pressures are anticipated even with the additional two feeds. This minimum pressure is within the allowable range of 40 psi (275kPa) to 100psi(700kPa).

Reliability – BSDY + Fire + Break

A reliability analysis was carried out to determine whether the distribution system is capable of providing adequate fireflows under an emergency watermain break scenario. This analysis was carried out using an overall BSDY demand. Two critical break locations were modeled.

The first break location was along the 406mm diameter feed on Tenth Line north of Lakepointe as shown in **Figure 8**. Under this emergency condition, fireflows between 13,000 and 30,000 Lpm could be provided to the MBC (not including fireflows on Tenth Line). In general, this means that the system would be capable of providing at least **13,000Lpm** to all locations along the trunk watermains in MBC under this failure scenario.

A second break location was created in the proposed 406mm diameter watermain along Lakepointe just west of Tenth Line as shown in **Figure 9**. This is considered to be the most critical situation as available flows drop to the **8,000 to 10,000 Lpm** range in the MBC due to only one 305mm diameter feeding the community.

## Stantec

March 15, 2006  
Bob Wingate, P. Eng.  
Page 6 of 6

### Reference: Mer Bleue Community Design Plan – Potable Water Hydraulic Analysis

A third reliability scenario considered the same failure described in the previous scenario along Lakepointe St. however it also included an upgrade to the Tenth Line watermain (to 406mm diameter) between Lakepointe St. and the 305mm diameter Blackburn Bypass (**Figure 10**). The results show that this upgrade improves the overall system, increasing available flows to the **10,000 to 13,000Lpm** range.

The last reliability scenario considered the same failure noted in previous scenario along Lakepointe with the Tenth Line upgrade (406mm diameter between Lakepointe St. and the 305mm diameter Blackburn Bypass) and included a link to the Notre Dame des Champs water distribution network in the southwest corner (**Figure 11**). This connection significantly improved the available flows to values over **18,000Lpm**.

### Conclusion

Stantec carried out a hydraulic analysis for the large diameter watermain network proposed for the MBC. Various demand conditions were modeled to determine anticipated flows and pressures under different network configurations. The results of this analysis indicate that the watermain network proposed in **Figure 12** is capable of providing appropriate flows throughout the community under typical, fire and emergency conditions. It is noted that in order to achieve commercial fireflows along Tenth Line (with a 152 mm diameter watermain), services will have to be looped into the commercial areas from the adjacent east-west large diameter watermains.

Should there be any questions regarding the findings presented in this letter, please contact the undersigned.


Yours truly,

**STANTEC CONSULTING LTD.**

Kevin Alemany, M.A.Sc., P.Eng.  
Environmental Engineer  
Tel: (613) 724-4091  
Fax: (613) 722-2799  
kalemany@stantec.com

ka v:\01-634\active\1634\_00620 n5 sanitary overflow\preliminary\correspondence\letter\ltr\_mer\_bleue\_cdp\_ka\_c15\_2006.doc

Figure 12: Recommended watermain diameters (mm) for MBC





## **Orleans Family Health Hub**

### **Stormwater Management & Servicing Report**

**Type of Document:**  
Site Plan Application

**Project Name:**  
Orleans Family Health Hub (OFHH)

**Project Number**  
OTT-00240132-A0

**Prepared By:**  
**exp** Services Inc.  
100-2650 Queensview Drive  
Ottawa, ON K2B 8H6  
Canada

**Date Submitted**  
April 5, 2018





- **Taggart Group of Companies**

### **Infrastructure Servicing Brief**

#### **Type of Document**

Issued for Site Plan Application

#### **Project Name**

Chaperal – Site Plan

#### **Project Number**

2762

#### **Prepared By:**

**exp** Services Inc.  
100-2650 Queensview Drive  
Ottawa, ON K2B 8H6  
Canada

#### **Date Submitted**

February 22, 2013  
August 22, 2013 – Revision 1  
October 8, 2013 – Revision 2  
**November 20, 2013 – Revision 3**



# WATERMAIN SCHEMATIC

## CHAPERAL – BLOCK '20'

Figure 2

